

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. FI/BAC/M/EC/2025

Dated: 01/09/2025

It is certified that an inspection team headed by Engineering Cell, Martam BAC
 (Name of Officers with designation) from Mr. Parkashewara Chellai (A.E.) Ongmu Lepela (J.E)
 (Name of Department/ Office) inspected the Bahai Sr. Sec. School, Saramsa
 (Name & Address of the school) on 28/08/2025 (date of inspection) and found that
 the Bahai Sr. Sec. School (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of Six Months.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : BAC, Martam

Assistant Engineer
 BAC
 Parkashewara Chellai
 A.E.
 Junior Engineer
 Martam
 Ongmu Lepela
 J.E, BAC
 Martam

To

Principal
 Bahai Sr. Sec. School

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

130

Chellai
 Manager
 BAHÁ'Í SCHOOL
 SARAMSA

[Signature]
 PRINCIPAL
 BAHÁ'Í SR. SEC. SCH.
 SARAMSA

TESTING REPORT OF RURAL DRINKING WATER SOURCE THROUGH FIELD

TESTING KIT (FTK)

NAME OF DISTRICT: Gangtok

BLOCK: Nandok

GRAM PANCHYAT: Nandok

VILLAGE: Jalipool Area

HABITATION: Tap Water

NAME OF SCHEME/SCHOOL/ICDS/HH: Baha'i Sr.Sec.School


DATE TIME OF SAMPLING: 28/08/2025 Time: 03:00

DATE TIME OF TESTING: 28/08/2025 Time: 03:35

TESTING READINGS

SL.NO	PARAMETERS	BIS LIMIT	TESTING READINGS SAFE/UNSAFE
1	Bacteriological (H2S Test)	Yellow: Absent Black: Present	Absent
2	Chlorine	0.2-1 mg/ltr	0.00mg\ltr
3	pH Value	6.5-8.5	7pH
4	Total Dissolve Solid (TDS)	500-1000 mg/ltr	600
5	Turbidity	1-5 NTU	1ntu
6	Chloride	-	250mg\ltr
7	Alkalinity	200-600 mg/ltr	300mg\ltr
8	Total Hardness	300-600 mg/ltr	400mg\ltr
9	Iron	1.0-3 mg/ltr	0.00mg\ltr
10	Fluoride	1.0-1.5 mg/ltr	0.00mg\ltr
11	Nitrate	45mg/ltr	0.00mg\ltr
12	Total Arsenic	0.01mg/ltr	N\A
13	Ammonia	0.5 mg/ltr	N\A
14	Sulphate		100mg/ltr

TESTED BY:


B.F.E

VERIFIED BY:


Assistant Engineer
BAC Martam


Principal
Bahá'í Senior Secondary School
Saramsa


Manager
BAHÁ'Í SCHOOL
SARAMSA